



**WASHTENAW COUNTY
FINANCE DEPARTMENT**

Purchasing Division

P.O. Box 8645, 220 N. Main, Ann Arbor, MI 48107-8645
Phone (734) 222-6760, Fax (734) 222-6764
www.purchasing.ewashtenaw.org

April 28, 2011

Addendum #1

RFP No.

6612

Title:

HVAC & Duct System Cleaning

Due Date:

Thursday, May 12, 2011 at 4:00PM

This addendum is generated due to various vendor questions.
Responses are attached.

Crystal A. Wake, CPPB, C.P.M.
Senior Buyer

cc: RFP 6612

QUESTIONS & ANSWERS

RFP #6612

Q1. Can we use a non-marking lift on gym floor or is scaffolding required?

Yes, the floor will support a lift, scaffolding is not required.

Q2. Will blueprints be made available?

Yes, prints will be available on Friday April 29th at the front desk in the Meri Lou Murray Recreation center on a CD.

Q3. Does this project include replacing filters?

Yes, owner will provide new filters and will dispose of the old ones.

Q4. What about cleaning in the fresh air intake alley?

Yes, clean the fresh air intake alley and clean off loose paint chips on high beams.

Q5. Will the balancing report for HVAC be made available?

Yes, owner will make report available for viewing.

Q6. What other rules and requirements must be followed?

OSHA AND MIOSHO requirements must be met. Parks does not have any other requirements above OSHA and MIOSHA aside what is already mentioned in the bid documents.

Q7. What about the exhaust from the restrooms?

Yes, the exhaust from the restrooms is part of this bid proposal.

Q8. Is the Chiller part of the bid proposal?

Yes, the chiller must be cleaned out.

Q9. How do we find out about the CUB agreement information?

Contact Bart Nickerson at the Washtenaw County Skilled Trades Council at: 734-944-5317 or cell at: 734-320-2227.