



**WASHTENAW COUNTY  
FINANCE DEPARTMENT**

**Purchasing Division**

P. O. Box 8645, 220 N. Main, Ann Arbor, MI 48107-8645  
Phone (734) 222-6760, Fax (734) 222-6764  
[www.purchasing.ewashtenaw.org](http://www.purchasing.ewashtenaw.org)

**June 27, 2011**

**Addendum #1**

RFP No. 6618  
Title: Variable Frequency Drives for Pool Pumps  
Due Date: Wednesday, July 13, 2011 at 4:00PM

This addendum is generated due to questions at mandatory walk through and clarification on pump quantities and horse power.

1. Questions and responses.
2. Clarification on quantities and HP on page 13. Please replace original page 13 with attached page 13 when submitting bid proposal.

Addendum MUST be included in bid proposal submission. Failure to submit addendum could result in disqualification.

Crystal A. Wake, CPPB, C.P.M.  
Senior Buyer

cc: RFP 6618

# ADDENDUM #1

## QUESTIONS & RESPONSES

### RFP #6618

**Q1. Will an analysis of the pumps be done prior to bid award?**

No, when award has been determined vendor will work with the County to determine most economical process per pump.

**Q2. How should the drives be mounted?**

Drives should be wall mounted, not on pedestals.

**Q3. Will a bypass be required on VFD?**

Yes.

**Q4. What is the voltage of the pumps at the Recreation Center?**

440 Volts.

It was also noted the motors on the pumps are a Class "B".

ADDENDUM #1

<b>BID SHEET</b>
------------------

**Please complete the following with Unit costs for each pump required and installation charges for a total amount. Please list any other charges in detail on space provided at the bottom.**

**VARIABLE FREQUENCY DRIVES (VFD) FOR POOL PUMPS**

TYPE	QTY	PUMP COSTS	INSTALLATION COSTS	TOTAL
<u>INDOOR</u>				
3 HP	2	\$	\$	\$
5 HP	1	\$	\$	\$
<u>OUTDOOR</u>				
7.5 HP	1	\$	\$	\$
10 HP	2	\$	\$	\$
15 HP	2	\$	\$	\$
20 HP	1	\$	\$	\$
25 HP	2	\$	\$	\$
30 HP	3	\$	\$	\$
40 HP	3	\$	\$	\$
60 HP	1	\$	\$	\$
<b>TOTAL AMOUNT</b>				<b>\$</b>

**REMARKS & OTHER CHARGES:**

---

---

---

---

---

---

---

---

---

---