



**ADDENDUM #1**

**RFP #6630  
Sharon Mills Pedestrian Bridge Rehabilitation  
Over the River Raisin**

for:  
**Washtenaw County  
Parks and Recreation Commission  
Ann Arbor, Michigan**

TO: All Bidders

SUBJECT: Addendum to the Bidding and Contract Document, dated July 14, 2011, are provided for the information of the eligible Bidders.

This Addendum is issued to provide clarification, before the bid opening date.

Project Name (location where the work is done) Sharon Mills, Sharon Township, Manchester, Washtenaw County, MI		
<b>BID OPENING Unchanged</b>	DATE <b>August 10, 2011</b>	TIME (local time) <b>3:00 p.m.</b>
<u>Summary of Bidder's Questions:</u>		
<u>Q1:</u> Can the handrail be cut?		
<u>Answer:</u> The handrails may be cut in order to be removed. However, following re-installation of the handrails the locations that were cut for removal shall be repaired by full penetration welds. The surface areas will be ground to provide a uniform surface that matches the existing. All areas cut, welded and ground shall be cleaned and painted. The contractor shall provide a paint system for approval. The paint system shall be a 3-coat system including a primer coat, an intermediate coat and a finish coat. The finish coat color shall match the existing handrail color as close as practicable.		
<u>Q2:</u> What is the intent for the stone wall under the bridge?		
<u>Answer:</u> The stone walls directly below the bridge (abutments), and the wingwalls (retaining walls) adjacent to the bridge shall be cleaned of all loose and deteriorated concrete. All stone to remain in place shall be re-pointed and mortared as part of this project. All portions of the abutments, wingwalls and piers are required to be sounded and marked for examination, and repaired as necessary in accordance with the notes and pay items on plan sheet 2 of 6.		
<b>PROJECT MANAGER'S NAME</b> Richard Kent, Washtenaw County Parks		<b>PROJECT MANAGER'S TELEPHONE NUMBER</b> (734) 971-6337 ext:319
<b>BIDDER'S ACKNOWLEDGMENT:</b>		
Firm name		
Bidder's signature and	date	Title
A copy of this Addendum, properly signed in the space provided above, must be returned <b>with</b> the bidder's proposal.		